



Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
ISO 9001 | ISO 14001 | ISO 45001



Test Report

Sample Number : VEL/N/2203280001

Report No. : VEL/N/2203280001

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Format No : 7.8 F-01

Party Reference No : By Mail

Reporting Date : 31/03/2022

Period of Analysis : 28/03/2022-31/03/2022

Receipt Date : 28/03/2022

Sample Description : DG Noise

General Information

Sampling Location : DG Set No-1(250 KVA)

Sample Collected By : VEL Representative (Mr. Sher Singh)

Sampling Equipment used : Sound Level Meter

Instrument Code : VEL/SLM/04

Instrument Calibration Status : Calibrated

Meteorological condition during monitoring : Clear Sky

Date of Monitoring : 26/03/2022

Scope of Monitoring : Regulatory Requirement

Sampling & Analysis Protocol : IS 9989

Sampling duration (Minutes) : 30.0

Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close th canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
1	Leq	CPCB Guidelines & Indian Standard:9989	95.8	70.2	25.6
2	CPCB Limit in Leq dB (A)	--	--	75.00 (Max.)	25.00 (Min.)

End of Report

(Checked By)

SUBODH SHEKHAWAT
Dy. Technical Manager

(Approved By)





Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
ISO 9001 | ISO 14001 | ISO 45001



Test Report

Sample Number : VEL/N/2203280002

Report No. : VEL/N/2203280002

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Format No : 7.8 F-01
Party Reference No : By Mail
Reporting Date : 31/03/2022
Period of Analysis : 28/03/2022-31/03/2022
Receipt Date : 28/03/2022

Sample Description : DG Noise

General Information

Sampling Location : DG Set No-2 (250 KVA)
Sample Collected By : VEL Representative (Mr. Sher Singh)
Sampling Equipment used : Sound Level Meter
Instrument Code : VEL/SLM/04
Instrument Calibration Status : Calibrated
Meteorological condition during monitoring : Clear Sky
Date of Monitoring : 26/03/2022
Scope of Monitoring : Regulatory Requirement
Sampling & Analysis Protocol : IS 9989
Sampling duration (Minutes) : 30.0
Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close th canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
1	Leq	CPCB Guidelines & Indian Standard:9989	96.1	70.2	25.9
2	CPCB Limit in Leq dB (A)	--	--	75.00 (Max.)	25.00 (Min.)

End of Report

(Checked By)
SUBODH SHEKHAWAT
Dy. Technical Manager





Vardan EnviroLab

Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
ISO 9001 | ISO 14001 | ISO 45001



Test Report

Sample Number : VEL/N/2203280003

Report No. : VEL/N/2203280003

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Format No : 7.8 F-01
Party Reference No : By Mail
Reporting Date : 31/03/2022
Period of Analysis : 28/03/2022-31/03/2022
Receipt Date : 28/03/2022

Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Liquid Plant
Sample Collected By : VEL Representative (Mr. Sher Singh)
Sampling Equipment used : Sound Level Meter
Instrument Code : VEL/SLM/05
Instrument Calibration Status : Calibrated
Meteorological condition during monitoring : Clear Sky
Date of Monitoring : 26/03/2022
Time of Monitoring : 01:00 PM to 01:30 PM
Surrounding Activity : Human & Others Activities
Scope of Monitoring : Regulatory Requirement
Control measure if Any : No
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
Sampling Duration : 30.0 Min.
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	82.1
2	Lmin	CPCB Guidelines & IS:9989	56.9
3	Leq.	CPCB Guidelines & IS:9989	76.3
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report

(Checked By)
SUBODH SHEKHAWAT
Dy. Technical Manager

(Approved By)
Authorised Signatory





Vardan EnviroLab



Laboratory: Plot No. 82A, Sector - 5, IMT Manesar, Gurugram - 122051 (Haryana)
ISO 9001 | ISO 14001 | ISO 45001

Test Report

Sample Number : VEL/N/2203280004 Report No. : VEL/N/2203280004
 Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd. Format No : 7.8 F-01
 49th Km Stone, Khasra No. 122, Mathura Road, Village Party Reference No : By Mail
 - Prithla, Dist - Palwal, Haryana (Haryana) Reporting Date : 31/03/2022
 Period of Analysis : 28/03/2022-31/03/2022
 Receipt Date : 28/03/2022

Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Dispatch Area
 Sample Collected By : VEL Representative (Mr. Sher Singh)
 Sampling Equipment used : Sound Level Meter
 Instrument Code : VEL/SLM/05
 Instrument Calibration Status : Calibrated
 Meteorological condition during monitoring : Clear Sky
 Date of Monitoring : 26/03/2022
 Time of Monitoring : 01:45 PM to 02:15 PM
 Surrounding Activity : Human & Vehicular Activities
 Scope of Monitoring : Regulatory Requirement
 Control measure if Any : No
 Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
 Sampling Duration : 30.0 Min.
 Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	78.4
2	Lmin	CPCB Guidelines & IS:9989	53.1
3	Leq.	CPCB Guidelines & IS:9989	72.6
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report

(Checked By)
SUBODH SHEKHAWAT
 Dy. Technical Manager

(Approved By)

 Authorized Signatory





Test Report

Sample Number : VEL/N/2203280005 Report No. : VEL/N/2203280005
 Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd. Format No. : 7.8 F-01
 49th Km Stone, Khasra No. 122, Mathura Road, Village Party Reference No. : By Mail
 - Prithla, Dist - Palwal, Haryana (Haryana) Reporting Date : 31/03/2022
 Period of Analysis : 28/03/2022-31/03/2022
 Receipt Date : 28/03/2022

Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Sledge Area
 Sample Collected By : VEL Representative (Mr. Sher Singh)
 Sampling Equipment used : Sound Level Meter
 Instrument Code : VEL/SLM/05
 Instrument Calibration Status : Calibrated
 Meteorological condition during monitoring : Clear Sky
 Date of Monitoring : 26/03/2022
 Time of Monitoring : 02:30 PM to 03:00 PM
 Surrounding Activity : Human & Vehicular Activities
 Scope of Monitoring : Regulatory Requirement
 Control measure if Any : No
 Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
 Sampling Duration : 30.0 Min.
 Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	76.2
2	Lmin	CPCB Guidelines & IS:9989	55.8
3	Leq.	CPCB Guidelines & IS:9989	71.4
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report

(Checked By)

SUBODH SHEKHAWAT
Dy. Technical Manager

(Approved By)

M. V. VIKRANT
Authorized Signatory





Test Report

Sample Number : VEL/N/2112290001

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2112290001

Format No : 7.8 F-01

Party Reference No : By Mail

Reporting Date : 03/01/2022

Period of Analysis : 29/12/2021-03/01/2022

Receipt Date : 29/12/2021


Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Dispatch Area
Sample Collected By : VEL Representative (Mr. Mukesh)
Sampling Equipment used : Sound Level Meter
Instrument Code : VEL/SLM/01
Instrument Calibration Status : Calibrated
Meteorological condition during monitoring : Clear Sky
Date of Monitoring : 28/12/2021
Time of Monitoring : 01:00 PM to 01:30 PM
Surrounding Activity : Human & Others Activities
Scope of Monitoring : Regulatory Requirement
Control measure if Any : No
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
Sampling Duration : 30.0 Min.
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	79.5
2	Lmin	CPCB Guidelines & IS:9989	53.6
3	Leq.	CPCB Guidelines & IS:9989	74.1
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report


(Checked By)
SUBODH SHEKHAWAT
Dy. Technical Manager





Test Report

Sample Number : VEL/N/2112290002

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2112290002

Format No : 7.8 F-01

Party Reference No : By Mail

Reporting Date : 03/01/2022

Period of Analysis : 29/12/2021-03/01/2022

Receipt Date : 29/12/2021

Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Sludge Area
Sample Collected By : VEL Representative (Mr. Mukesh)
Sampling Equipment used : Sound Level Meter
Instrument Code : VEL/SLM/01
Instrument Calibration Status : Calibrated
Meteorological condition during monitoring : Clear Sky
Date of Monitoring : 28/12/2021
Time of Monitoring : 01:45 PM to 02:15 PM
Surrounding Activity : Human & Others Activities
Scope of Monitoring : Regulatory Requirement
Control measure if Any : No
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
Sampling Duration : 30.0 Min.
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	83.5
2	Lmin	CPCB Guidelines & IS:9989	51.6
3	Leq.	CPCB Guidelines & IS:9989	78.2
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report

SUBODH SHEKHAWAT
(Checked By)
Dy. Technical Manager





Test Report

Sample Number : VEL/N/2112290003

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.
49th Km Stone, Khasra No. 122, Mathura Road, Village
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2112290003

Format No : 7.8 F-01

Party Reference No : By Mail

Reporting Date : 03/01/2022

Period of Analysis : 29/12/2021-03/01/2022

Receipt Date : 29/12/2021

Sample Description : Workzone Noise Monitoring

General Information

Sampling Location : Liquid Plant
Sample Collected By : VEL Representative (Mr. Mukesh)
Sampling Equipment used : Sound Level Meter
Instrument Code : VEL/SLM/01
Instrument Calibration Status : Calibrated
Meteorological condition during monitoring : Clear Sky
Date of Monitoring : 28/12/2021
Time of Monitoring : 02:30 PM to 03:00 PM
Surrounding Activity : Human & Others Activities
Scope of Monitoring : Regulatory Requirement
Control measure if Any : No
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989
Sampling Duration : 30.0 Min.
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Lmax	CPCB Guidelines & IS:9989	75.1
2	Lmin	CPCB Guidelines & IS:9989	56.8
3	Leq.	CPCB Guidelines & IS:9989	71.4
4	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

End of Report

(Checked By)

SUBODH SHEKHAWAT
Dy. Technical Manager

