



## Test Report

Page No. 1/1

Sample Number : VEL/N/04

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2306240004

Format No : 7.8 F-03

Party Reference No : By Mail

Reporting Date : 30/06/2023

Period of Analysis : 24/06/2023-30/06/2023

Receipt Date : 24/06/2023

Sample Description : DG Noise

### General Information

Sampling Location : DG Set No-1 (250 KVA)  
Sample Collected By : VEL Representative (Mr. Sher Singh)  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/05  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 22/06/2023  
Scope of Monitoring : Regulatory Requirement  
Sampling & Analysis Protocol : IS 9989  
Sampling duration (Minutes) : 30.0  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close the canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
1	Leq	CPCB Guidelines & Indian Standard:9989	98.7	73.0	25.7
2	CPCB Limit in Leq dB (A)	--	--	75.00 (Max.)	25.00 (Min.)

\*\*\*End of Report\*\*\*

(Checked By)

(Approved By)  
Prithvi Singh

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period.
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Sample Number : VEL/N/05

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.

49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2306240005

Format No : 7.8 F-03

Party Reference No : By Mail

Reporting Date : 30/06/2023

Period of Analysis : 24/06/2023-30/06/2023

Receipt Date : 24/06/2023


Sample Description : DG Noise

### General Information

Sampling Location : DG Set No-2 (250 KVA)  
 Sample Collected By : VEL Representative (Mr. Sher Singh)  
 Sampling Equipment used : Sound Level Meter  
 Instrument Code : VEL/SLM/05  
 Instrument Calibration Status : Calibrated  
 Meteorological condition during monitoring : Clear Sky  
 Date of Monitoring : 22/06/2023  
 Scope of Monitoring : Regulatory Requirement  
 Sampling & Analysis Protocol : IS 9989  
 Sampling duration (Minutes) : 30.0  
 Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close the canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
1	Leq	CPCB Guidelines & Indian Standard:9989	97.5	71.4	26.1
2	CPCB Limit in Leq dB (A)	--	--	75.00 (Max.)	25.00 (Min.)

\*\*\*End of Report\*\*\*

  
 (Checked By)  
 30/06/2023

  
 (Approved By)

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/AP/08

Report No. : VEL/AP/2310180008

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Format No : 7.8 F-03

Party Reference No : By Mail

Reporting Date : 25/10/2023

Period of Analysis : 18/10/2023-25/10/2023

Receipt Date : 18/10/2023

Name of Sample : DG Noise

Sample Group : Atmospheric Pollution

### General Information

Sampling Location : DG Set No.1 (125 KVA)  
Sample Collected By : VEL Representative (Mr. Dilver )  
Sampling Equipment used : Sound Level Meier  
Instrument Code : VEL/SLM/02  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 17/10/2023  
Scope of Monitoring : Regulatory Requirement  
Sampling & Analysis Protocol : IS 4758  
Sampling duration (Minutes) : 30.0  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close the canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
Discipline : Chemical					
1	Leq	IS: 4758	96.7	71.0	25.7
2	CPCB Limit in Leq dB (A)	--	--	75.0 (Max.)	25.0 (Min.)

\*\*\*End of Report\*\*\*



Reviewed By



Authorized Signatory

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/AP/09

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/AP/2310180009

Format No : 7.8 F-03

Party Reference No : By Mail

Reporting Date : 25/10/2023

Period of Analysis : 18/10/2023-25/10/2023

Receipt Date : 18/10/2023

Name of Sample : DG Noise

Sample Group : Atmospheric Pollution

### General Information

Sampling Location : DG Set No.2 (125 KVA)  
Sample Collected By : VEL Representative (Mr. Dilver )  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/02  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 17/10/2023  
Scope of Monitoring : Regulatory Requirement  
Sampling & Analysis Protocol : IS 4758  
Sampling duration (Minutes) : 30.0  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Open the canopy of DG Set Results dB(A)	Close the canopy of DG Set (1.0 mtr. Distance) Result dB(A)	Insertion Loss
Discipline : Chemical					
1	Leq	IS: 4758	97.5	71.4	26.1
2	CPCB Limit in Leq dB (A)	--	--	75.0 (Max.)	25.0 (Min.)

\*\*\*End of Report\*\*\*

Reviewed By  
  
Kumar

Authorized Signatory  
  
Ganraj Prasad

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/N/01

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2306240001

Format No : 7.8 F 03

Party Reference No : By Mail

Reporting Date : 30/06/2023

Period of Analysis : 24/06/2023-30/06/2023

Receipt Date : 24/06/2023


Sample Description : Workzone Noise Monitoring


### General Information

Sampling Location : Sledge Area  
Sample Collected By : VEL Representative (Mr. Sher Singh)  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/05  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 22/06/2023  
Time of Monitoring : 11:30 AM to 02:01 PM  
Surrounding Activity : Human & Others Activities  
Scope of Monitoring : Regulatory Requirement  
Control measure if Any : No  
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989  
Sampling Duration : 151.0 Min.  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Leq.	CPCB Guidelines & IS:9989	73.44
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*

(Checked By)   
30/06/2023

(Approved By) 

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period.
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/N/02

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2306240002

Format No : 7.8 F 03

Party Reference No : By Mail

Reporting Date : 30/06/2023

Period of Analysis : 24/06/2023-30/06/2023

Receipt Date : 24/06/2023

Sample Description : Workzone Noise Monitoring

### General Information

Sampling Location : Dispatch Area  
Sample Collected By : VEL Representative (Mr. Sher Singh)  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/05  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 22/06/2023  
Time of Monitoring : 02:15 PM to 04:46 PM  
Surrounding Activity : Human & Others Activities  
Scope of Monitoring : Regulatory Requirement  
Control measure if Any : No  
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989  
Sampling Duration : 151.0 Min.  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Leq.	CPCB Guidelines & IS:9989	68.69
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*

(Checked By) *Kumar*  
30/06/2023

(Approved By) *Gaurav*

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/N/03

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/N/2306240003

Format No : 7.8 F 03

Party Reference No : By Mail

Reporting Date : 30/06/2023

Period of Analysis : 24/06/2023-30/06/2023

Receipt Date : 24/06/2023

Sample Description : Workzone Noise Monitoring

### General Information

Sampling Location : Liquid Plant  
Sample Collected By : VEL Representative (Mr. Sher Singh)  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/05  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 22/06/2023  
Time of Monitoring : 05:00 PM to 07:31 PM  
Surrounding Activity : Human & Others Activities  
Scope of Monitoring : Regulatory Requirement  
Control measure if Any : No  
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989  
Sampling Duration : 151.0 Min.  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
1	Leq.	CPCB Guidelines & IS:9989	71.52
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*

(Checked By)

(Approved By)

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/AP/13  
 Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
 49th Km Stone, Khasra No. 122, Mathura Road, Village - Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/AP/2310180013  
 Format No : 7.8 F 03  
 Party Reference No : By Mail  
 Reporting Date : 25/10/2023  
 Period of Analysis : 18/10/2023-25/10/2023  
 Receipt Date : 18/10/2023

Name of Sample : Workzone Noise Monitoring  
 Sample Group : Atmospheric Pollution

**General Information**

Sampling Location : Liquid Plant  
 Sample Collected By : VEL Representative (Mr. Dilver )  
 Sampling Equipment used : Sound Level Meter  
 Instrument Code : VEL/SLM/02  
 Instrument Calibration Status : Calibrated  
 Meteorological condition during monitoring : Clear Sky  
 Date of Monitoring : 17/10/2023  
 Time of Monitoring : 11:00 PM to 01:31 PM  
 Surrounding Activity : Human & Others Activites  
 Scope of Monitoring : Regulatory Requirement  
 Control measure if Any : No  
 Sampling & Analysis Protocol : CPCB Guidelines & IS-9989  
 Sampling Duration : 151.0 Min.  
 Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
Discipline : Chemical			
1	Leq.	CPCB Guidelines & IS:9989	73.20
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*



### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.







## Test Report

Page No. 1/1

Sample Number : VEL/AP/14

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Report No. : VEL/AP/2310180014

Format No : 7.8 F 03

Party Reference No : By Mail

Reporting Date : 25/10/2023

Period of Analysis : 18/10/2023-25/10/2023

Receipt Date : 18/10/2023

Name of Sample : Workzone Noise Monitoring

Sample Group : Atmospheric Pollution

### General Information

Sampling Location	: Dispatch Area
Sample Collected By	: VEL Representative (Mr. Dilver )
Sampling Equipment used	: Sound Level Meter
Instrument Code	: VEL/SLM/02
Instrument Calibration Status	: Calibrated
Meteorological condition during monitoring	: Clear Sky
Date of Monitoring	: 17/10/2023
Time of Monitoring	: 01:45 PM to 03:16 PM
Surrounding Activity	: Human & Others Activites
Scope of Monitoring	: Regulatory Requirement
Control measure if Any	: No
Sampling & Analysis Protocol	: CPCB Guidelines & IS-9989
Sampling Duration	: 151.0 Min.
Parameter Required	: As per work order

S.No.	Parameters	Test Method	Results
Discipline : Chemical			
1	Leq.	CPCB Guidelines & IS:9989	69.75
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*



Reviewed By



Authorized Signatory

### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period.
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.





## Test Report

Page No. 1/1

Sample Number : VEL/AP/15

Report No. : VEL/AP/2310180015

Name & Address of the Party : M/s Maharani Innovative Paints Pvt. Ltd.  
49th Km Stone, Khasra No. 122, Mathura Road, Village  
- Prithla, Dist - Palwal, Haryana (Haryana)

Format No : 7.8 F 03  
Party Reference No : By Mail  
Reporting Date : 25/10/2023  
Period of Analysis : 18/10/2023-25/10/2023  
Receipt Date : 18/10/2023


Name of Sample : Workzone Noise Monitoring  
Sample Group : Atmospheric Pollution

### General Information

Sampling Location : Sledge Area  
Sample Collected By : VEL Representative (Mr. Dilver )  
Sampling Equipment used : Sound Level Meter  
Instrument Code : VEL/SLM/02  
Instrument Calibration Status : Calibrated  
Meteorological condition during monitoring : Clear Sky  
Date of Monitoring : 17/10/2023  
Time of Monitoring : 04:30 PM to 07:01 PM  
Surrounding Activity : Human & Others Activites  
Scope of Monitoring : Regulatory Requirement  
Control measure if Any : No  
Sampling & Analysis Protocol : CPCB Guidelines & IS-9989  
Sampling Duration : 151.0 Min.  
Parameter Required : As per work order

S.No.	Parameters	Test Method	Results
Discipline : Chemical			
1	Leq.	CPCB Guidelines & IS:9989	71.75
2	CPCB Limit in Leq dB(A) (Factory Limit)	---	90

\*\*\*End of Report\*\*\*



### Terms & Conditions

- The results reported relate only to the samples tested. In case sample is not drawn the results apply to the sample as received.
- This test report in full or in part, shall not be reproduced in any court of law without prior written approval of the laboratory.
- To confirm the authenticity of this certificate of analysis, please contact us through email at lab@vardan.co.in
- Laboratory is not responsible for the authenticity of photocopied test report. The test samples will be retained only for specific period
- The report no. with Suffix A-Amended Report.
- This test report will not be used for publicity or advertising or media purpose without prior written permission on the laboratory.
- Giving opinions does not imply endorsement of the tested sample by the lab. Under no circumstances, the lab accepts any liability caused by the use or misuse of the test report.

